



Public Health Laboratory

Surat Municipal Corporation
2nd Floor, Vesu Urban Community-Health Center
Opp. Vesu Fire Station, VIP Road,
Vesu, Surat -395007 Gujarat

Name And Address of Applicant-	Lourdes Convent School Opp- Indoor Stadium, Athwalines, Surat.			Report No.	No.Q-2/PHL/WC/F-336/2024-25
				Receipt No.	496835
				ULR No.	-
				Date of Sample	11/06/2024
Type of Sample:-	Private	Register Entry No.	336	Start Date of Analysis	12/06/2024
Source of the Water:-	Drinking Water			End Date of Analysis	12/06/2024

Test Report

Sample Description :- A plastic bottle

Physical Appearance: - Clear Liquid

Loose

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.		Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.		Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.	-	8.0	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent	Max 0.5
6.	Nitrate (as NO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.3.	mg/l	Absent	Max 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	80.0	Max. 250
8.	Total Alkalinity (as Calcium Carbonate)	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	185.0	Max 200
9.	Total hardness (as CaCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	155.0	Max 200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	420.0	Max 500

Opinion: With respect to the test and observation performed, above sample of Drinking Water (Tank Water) conforms to the standards and provisions of Food Safety and Standard Act, 2006 and FSS Rules & Regulations.

.....end of the test report.....

Report Issue Date :- 14/06/2024



Food Analyst
Public Health Laboratory
Surat Municipal Corporation
Surat

Note:-
Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.



No.PHD/PI/ 143
Dt.28/06/2024

SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

It is certified that an inspection team headed by Mr. J.P.Raval, Sanitary Inspector from Health Department inspected LOURDES CONVENT School (CBSE), situated at Opp. Indoor Stadium, Athwalines, Surat on Dt. 28/06/2024 and found that the **LOURDES CONVENT School (CBSE)** has Safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State govt.

The above is valid for a period of one year from the Date of issue.

Pradeep H. Umrigar

Dr. Pradeep H. Umrigar
Medical Officer of Health
Health Department
Surat Municipal Corporation

To,
Principal
LOURDES CONVENT School (CBSE)
Opp. Indoor Stadium,
Athwalines,
Surat.